



CITY OF

ELYRIA

OHIO 44035

THE PROGRESSIVE CITY

147648

LONNY G. SHIPPY, P.E.
CITY ENGINEER
328 BROAD STREET
PHONE 322-5464

March 27, 1979

Mr. James Freeman
Chemical Recovery Systems, Inc.
142 Locust Street
Elyria, Ohio 44035

Re: Storm Sewer

Dear Mr. Freeman:

A thorough recent review of the condition of the storm sewer pipe which runs from Locust Street to the Black River just north of your plant has been made by a staff member of the City Engineering Division. The film strips taken of the inside of the pipe showed broken sewer pipe near the river bank. From my review of the information assembled, I have concluded that the storm sewer pipe has probably suffered damage from past filling and/or grading actions undertaken or allowed by you or your predecessors on your property.

You are hereby notified that you shall cease any activities that will change the soil loading on the subject storm sewer, unless you have received written approval from this office. Should the storm sewer pipe collapse and cease to function, I am of the opinion that under the circumstances, your firm will be responsible for the proper repair and/or replacement of the storm sewer pipe as well as any damages to a third party which may result from the said sewer failure. If for your convenience, you should desire the relocation of the storm sewer pipe, I am of the opinion that you would be fully responsible for this work.

The film strip also shows three possible lateral connections from your property. Please contact Mr. Fullgrabe at 322-5464 to arrange for the inspection of your tracing of the lateral connections on your property, so that it can be determined that the laterals are being used only for allowable discharge to the river.

Should you desire to review the film strip of the inside of the pipe, please contact Mr. William Fullgrabe to arrange to review the film.

Mr. James Freeman
Chemical Recovery Systems, Inc.
March 27, 1979
Page 2 of 2

Please acknowledge the receipt of this letter by signing and returning the enclosed second copy of this letter.

Yours truly,

THE CITY OF ELYRIA, OHIO



Lonny G. Shippy, P.E.
City Engineer

LGS:nt

cc: Mr. Richard J. Bergman, Safety-Service Director
Mr. Ernest Bartha, Member City Pollution Control Board ✓
Mr. Charles Coen, Member City Pollution Control Board
Mr. Archie Evans, City Building Inspector
Mr. Vince Howard, Fire Department
file

I hereby acknowledge receipt of the above letter.

By _____ Title _____

Company _____ Date _____